## INVITATION TO BID Addendum # 3



Department Of Executive Services
Finance and Business Operations Division
Procurement and Contract Services Section
206-684-1681 TTY RELAY: 711

ADDENDUM DATE: May 5, 2006

ITB Title: Park Bridges - Pedestrian/Stock

ITB Number: 06-054 PXR

Revised Due Date/Time: May 11, 2006

Buyer: Paul Russell, paul.russell@metrokc.gov, 206-684-1054

Q#	Subsection	Question	Response
1	Section 6 Bid Price	Page 3 states to exclude all taxes from the bid price. Page 17 states to include necessary taxes in bid price. Which is it?	CLARIFICATION  Delete reference to taxes in bid price.  DELETE  Include in your price above any applicable taxes, freight, delivery (FBO to location below), etc.  REPLACE WITH  Include in your price above any applicable taxes (except Sales Tax), fees, freight, delivery (FBO to location below), etc.
2	Section 5 Technical Specifications	Concerning treatment (everything will be BMP of course), ACQ can be the treatment for all sawn lumber. Copper Napthenate can be the treatment for all glulam (stringers) because ACQ cannot be certified for laminated products. There will be a color discrepancy between these two treatments. Is this concerning to you?	CLARIFICATION  The following County Hydraulic Project permit language referred to the Western Wood Preservers Institute <a href="http://www.wwpinstitute.org/">http://www.wwpinstitute.org/</a> – Best Management Practices (BPM). <a href="mailto:BMP">BMP - Best</a> Management Practices for the use of Treated Wood in Aquatic Environments and <a href="mailto:BMP">BMP</a> Amendment #1 - ACZA April 18, 2002  The County at this time is not certifying, at this time, that the treatment plan in the question is the only approved wood treatment. The County is aware that there may be a difference in the color or hue of the woods in the bridge kit due to the treatment recommendation in the (BMP).